

AIR FLOW AND TEMPERATURE TRANSMITTER IVLJ 02

IVLJ 02 transmitter is designed for HVAC applications. Output signals correspond to the air flow velocity and temperature inside the ventilation duct.

Probe of the transmitter is mounted in the duct, on a place where the air flow is as laminar as possible. The transmitter should be mounted a suitable place near the probe. Linear and air flow proportional measuring signal is produced by comparing the sensor element temperatures. Both outputs can be separately selected to be either 4...20 mA or 0...10 V outputs.

The N model display resolution is 0,1 m/s for velocity and 0,1 °C for temperature. The display can be added also after commissioning. The measurement values scroll on the display. The wanted value can be locked to view continuously by removing the jumper on back of the display board.

IVLJ 02 is also available with a 100 and 400 mm long probe stem.

Output signal selection

	420 mA	* 010 V
out 1	•	•
out 2	•	•
* = factory :	setting	1

Wiring





Technical data

24 Vac (22...28 V), < 1.5 VA Supply 24 Vdc (23...28 V), < 1.5 W

Ranges

velocity 0...2 m/s temperature 0...50 °C

measuring range < 0.1 m/s \pm 7 % from reading (at 25 °C)

temperature $< 0.5 \, ^{\circ}\text{C} \, (25 \, ^{\circ}\text{C}, > 0.5 \, \text{m/s})$

Outputs 0...10 V, < 2 mA, 4...20 mA, < 600 Ω

Probe cable 2 m

Ambient temperature

0...50 °C

Mounting

probe by a flange, adjustable depth (200 mm

transmitter with screws, external lugs

Protection class IP 54 (transmitter), cable glands down-

Materials PBT, PC, PA and stainless steel

Ordering guide:

Model	Product number	Description
IVLJ 02	1130040	air flow transmitter 02 m/s, immersion depth 50190 mm
IVLJ 02-100	1130044	air flow transmitter, immersion depth 5090 mm
IVLJ 02-400	1130041	air flow transmitter, immersion depth 50390 mm

Products fulfil the requirements of directive 2004/108/EC and are in accordance with the standards EN61000-6-3: 2001 (Emission) and EN61000-6-2: 2001 (Immunity).



AIR FLOW AND TEMPERATURE TRANSMITTER IVLJ 10

IVLJ 10 transmitter is designed for HVAC applications. Output signals correspond to the air flow velocity and temperature inside the ventilation duct.

Probe of the transmitter is mounted in the duct, on a place where the air flow is as laminar as possible. The transmitter should be mounted a suitable place near the probe. Linear and air flow proportional measuring signal is produced by comparing the sensor element temperatures. Both outputs can be separately selected to be either 4...20 mA or 0...10 V outputs.

The N model display resolution is 0,1 m/s for velocity and 0,1 °C for temperature. The display can be added also after commissioning. The measurement values scroll on the display. The wanted value can be locked to view continuously by removing the jumper on back of the display board.

IVLJ 10 is also available with a 100 and 400 mm long probe stem.

Output signal selection

	420 mA	* 010 V
out 1	•	•
out 2	•	•
* = factory	setting	1

Wiring





Technical data

Supply 24 Vac (22...28 V), < 1.5 VA 24 Vdc (23...28 V), < 1.5 W

Ranges

velocity 0...10 m/s temperature 0...50 °C

Accuracy

measuring range $< 0.5 \text{ m/s} \pm 7 \%$ from reading (at 25 °C)

temperature $< 0.5 \,^{\circ}\text{C} \, (25 \,^{\circ}\text{C}, > 0.5 \,^{\text{m/s}})$

Outputs 0...10 V, < 2 mA, 4...20 mA, < 600 Ω

Probe cable 2 m Ambient temperature 0...50 °C

Mounting

probe by a flange, adjustable depth (200 mm

stem)

transmitter with screws, external lugs

Protection class IP 54 (transmitter), cable glands down-

wards

Materials PBT, PC, PA and stainless steel

Ordering guide:

ModelProduct numberDescriptionIVLJ 101130090air flow transmitter 0...10 m/s, immersion depth 50...190 mmIVLJ 10-1001130094air flow transmitter, immersion depth 50...90 mmIVLJ 10-4001130091air flow transmitter, immersion depth 50...390 mm

Products fulfil the requirements of directive 2004/108/EC and are in accordance with the standards EN61000-6-3: 2001 (Emission) and EN61000-6-2: 2001 (Immunity).



AIR FLOW AND TEMPERATURE TRANSMITTER IVLJ 20

IVLJ 20 transmitter is designed for HVAC applications. Output signals correspond to the air flow velocity and temperature inside the ventilation duct.

Probe of the transmitter is mounted in the duct, on a place where the air flow is as laminar as possible. The transmitter should be mounted a suitable place near the probe. Linear and air flow proportional measuring signal is produced by comparing the sensor element temperatures. Both outputs can be separately selected to be either 4...20 mA or 0...10 V outputs.

The N model display resolution is 0,1 m/s for velocity and 0,1 °C for temperature. The display can be added also after commissioning. The measurement values scroll on the display. The wanted value can be locked to view continuously by removing the jumper on back of the display board.

IVLJ 20 is also available with a 100 and 400 mm long probe stem.

Output signal selection

	420 mA	* 010 V		
out 1	•	•		
out 2	•	•		
* - factor coeffice				

* = factory setting

Wiring





Technical data

Supply 24 Vac (22...28 V), < 1.5 VA 24 Vdc (23...28 V), < 1.5 W

Ranges

velocity 0...20 m/s temperature 0...50 °C

Accuracy

measuring range $< 1 \text{ m/s} \pm 7 \text{ % from reading (at } 25 \text{ °C})$

temperature < 0.5 °C (25 °C, > 0.5 m/s)

Outputs 0...10 V, < 2 mA, 4...20 mA, < 600 Ω

Probe cable 2 m Ambient temperature 0...50 °C

Mounting

probe by a flange, adjustable depth (200 mm

stem)

transmitter with screws, external lugs

Protection class IP 54 (transmitter), cable glands down-

wards

Materials PBT, PC, PA and stainless steel

Ordering guide:

ModelProduct numberDescriptionIVLJ 201130100air flow transmitter 0...20 m/s,
immersion depth 50...190 mmIVLJ 20-1001130104air flow transmitter, immersion
depth 50...90 mmIVLJ 20-4001130101air flow transmitter, immersion
depth 50...390 mm

Products fulfil the requirements of directive 2004/108/EC and are in accordance with the standards EN61000-6-3: 2001 (Emission) and EN61000-6-2: 2001 (Immunity).